



Product Substitution Request

Submitted To: _____
 Project: _____
 Specified Item: _____

Specification Section: **Masonry Accessories**
 Proposed Substitution: **York 304 SA Self Adhering Stainless Steel**

Performance Characteristics		
	Rubberized Asphalt	York 304 SA Self Adhering Stainless Steel
Base Material	Petroleum	Stainless Steel
Puncture (ASTM E154)	80 psi	2,500+ psi
Tensile Strength (ASTM D412)	1,200 psi	100,000 psi
UV Exposure (days)	30	Unlimited
Recycled Material	1%	60%
Application Temperature	40°F to 120°F	20° F to 170° F

Technical data sheet includes product description, specifications, performance and test data adequate for evaluation of the request. If not present, is available at www.yorkmfg.com or 1-800-551-2828

The undersigned certifies that the following paragraphs, unless modified by attachments, are correct:

1. The proposed substitution does not affect dimensions shown on drawings.
2. The proposed substitution will have no adverse effect on the other trades, the construction schedule, or specified warranty requirements.
3. Local support and availability will be available for proposed substitution.
4. Mock-up wall materials available upon request.

The undersigned further states that the function and quality of the proposed product substitution is equivalent or superior to the specified item.

SUBMITTED BY

Name: _____ Title: _____
 Firm: _____ Address: _____
 Phone: _____ E-mail: _____
 Signature: _____ Date: _____
 Remarks: _____

A&E REVIEW

- Accepted
- Not Accepted
- Accepted as noted

Remarks: _____
 Reviewed by: _____ Date: _____